

5. The Management has provided the following Fire Fighting Systems as per the table 23 of Part – IV of NBC of India 2005.

Sl. No.	Fire Safety Measures	Required as per Table 23 Part – IV, of NBC Of India 2005	Provided	Deficit
		04 Nos	04 Nos	Nil
1	Fire Buckets	15 No's	15 No's	Nil
2	Fire Extinguishers	06 No's	06 No's	Nil
3	Hose Reel	10,000 Ltrs	20,000 Ltrs	Nil
4	Terrace water Tank	450 LPM	450 LPM	Nil
5	Booster Pump	Not Required	40,000 Ltrs	Nil
6	Underground Tank			

6. The above Fire Fighting System item wise randomly tested and found in good working condition.

In view of the above **Fire No Objection Certificate** for occupancy is issued for the Existing above College Building subject to the following conditions.

1. The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules/Govt. Orders as applicable.
2. Evacuation plan showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited at all times, all escape/exit routes shall not be blocked or encroached.
3. Fresh NOC would be required for any change in occupancy as per NBC and building bye/laws.
4. The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
5. Any Loss of fire or property due to Non – functioning of Fire Safety Measures and other installations shall be the responsibility of the Management/owner.
6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. All Occupants/Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
8. The Fire Drills shall be conducted once in every six months.

The Management has remitted Fire Precautionary fees vide challan No.26308 Dt:15-07-2015 for Rs.10,000/- at SBH, Treasury Branch, Hanamkonda.

This Renewal of Fire No Objection Certificate is valid from 23-08-2015 to 22-08-2016 and It is the responsibility of the Owner/Occupier to apply for renewal of Fire NOC, one month before expiry of Renewal of Fire NOC.


Commissioner,
GWMC - Warangal.

Copy to:

1. The Correspondent of M/s St. Peters College of Teacher Education D.Ed& B.Ed run by St. Peters Educational Association, H.No.2-4-1211, Vidyanagar, T.V. Tower, Hanamkonda.
2. Regional Fire Officer, Fire Prevention Wing, Warangal Municipal Corporation.